



**CANA**

**WASTEWATER TREATMENT PLANT**



**2018 ANNUAL REPORT**

## Contents

REPORT CHECK LIST .....	3
EXECUTIVE SUMMARY .....	4
PLANT OVERVIEW .....	4
Raw Sewage Pumping Station .....	4
Preliminary Treatment unit .....	4
Secondary Treatment Unit .....	4
Post Equalization Tank.....	5
Chemical Dosing system.....	5
Tertiary Filtration Unit.....	5
Ultra Violet (UV) Disinfection .....	5
Outfall.....	5
Building and Control Room .....	5
Digester Unit.....	5
PLANT PERFORMANCE .....	6
Table 1: Effluent Objective .....	6
Table 2: Monthly Average Results.....	7
Table 3: Plant Flows.....	8
Table 4: Surface Water Monitoring.....	8
Table 5: Reportable Bypasses .....	8
Table 6: Reportable Bypass Sampling .....	9
OPERATING PROBLEMS.....	9
SLUDGE GENERATED.....	9
MAINTENANCE.....	9
CAPITAL WORKS .....	9
OPERATIONS .....	10
EQUIPMENT CALIBRATIONS .....	10
COMPLAINTS.....	10
BYPASS .....	10

## REPORT CHECK LIST

Annual report submitted for the Environmental Compliance Approval number 4021-9WUKDE.

Condition 11(6). The first annual report shall cover the period from the commencement of operation of the sewage works to the end of the calendar year and shall be submitted within sixty (60) days following the end of such reporting period. Each subsequent annual report shall be submitted within sixty (60) days following the end of the calendar year being reported upon.

Condition 11(6)(a)to(l). Each annual report shall contain at least the following information:

- ✓ Executive Summary;
- ✓ Tabulation and comprehensive interpretation of all monitoring data and analytical results collected during the reporting period, and a comparison to the effluent quality and quantity;
- ✓ Summary of all maintenance carried out on any major structure, equipment, apparatus, mechanism or thing forming part of the works;
- ✓ Description of all operating problems encountered and corrective actions taken during the reporting period;
- ✓ Evaluation of the calibration and maintenance procedures conducted on all monitoring equipment;
- ✓ A tabulation of the volume of sludge generated, an outline of anticipated volumes to be generated in the next reporting year
- ✓ Summary of effluent quality assurance or control measures under taken;
- ✓ Summary of any complaints;
- ✓ Summary of all by-passes;
- ✓ A copy of all Notice of Modifications submitted to the Water Supervisor

## EXECUTIVE SUMMARY

ECA # 4021-9WUKDE was issued on July 22, 2015 for the new constructed WWTP plant to replace the 44 year old plant.

Utilities Kingston had previously completed an Environmental Study for solutions to address the aging Cana WWTP in June 2013. The study identified that a new sewage treatment system using SBR (Sequencing Batch Reactor) technology would be the chosen alternative to replace the existing Cana WWTP. The replacement SBR system has incorporated chemical / physical phosphorus removal and increased design capacity for the facility. The new sewage works has a rated capacity of 125 m<sup>3</sup>/d, and a maximum day design flow of 200 m<sup>3</sup>/d.

The average flow through the plant was 126.83 m<sup>3</sup>/d in 2018.

We have continued to provide cross training to staff members from other facilities and allow them to increase their knowledge of the new Cana WWTP process.

## PLANT OVERVIEW

The following is a process overview and description of the treatment steps taken at the CANA wastewater treatment plant.

### Raw Sewage Pumping Station

A pre-cast concrete wet well accepts sewage flows from existing sewer system via a new influent manhole, equipped with two pumps, one for duty and one for standby discharging to the preliminary treatment unit. The wet well has a control system and liquid level control system with alarms.

### Preliminary Treatment unit

The first step in the treatment process is the removal of large particles and floating debris such as wood, rags and plastics from the raw water. This is accomplished by the preliminary treatment unit which consists of a splitter box housing a 15mm manual bar screen, sized to handle the peak instantaneous flow of 4.6 L/sec. The splitter box has adjustable weir plates and a perforated drip tray. The flow goes from here to the sequencing batch reactors (SBR).

### Secondary Treatment Unit

The second operation is the secondary treatment unit which consists of two sequencing batch reactors (SBR). Each reactor is filled with raw sewage and then mixed and aerated to react (bacteria feeding on waste). Once the reaction has occurred the solids are settled and the water is decanted off the top and sent to the post equalization tank. Some of the sludge that collects on the bottom of the tank is pumped out for wasting while the rest goes to the digester unit for further treatment. The process is started over again. Each tank operates at a different time so there is a tank always collecting the raw sewage.

## **Post Equalization Tank**

The post equalization tank collects the decanted water from the sequencing batch reactors and discharges to the tertiary filter system.

## **Chemical Dosing system**

The chemical dosing system has alum dosing for Phosphorus removal. The alum is injected ahead of a static mixer. There is also a polymer dosing system used for filter aid. The polymer is injected in the SBR effluent after the static mixer.

## **Tertiary Filtration Unit**

The discharge of the post equalization tanks goes into a continuous backwash up-flow sand filter to polish the water before going through the ultra violet disinfection system.

## **Ultra Violet (UV) Disinfection**

There are two UV disinfection units in parallel, each can handle the maximum flow of 200 m<sup>3</sup>/day.

## **Outfall**

The treated effluent from the plant is discharged into a 27.9 meter long pipe into an existing watercourse that conveys flow into Colonel by Lake.

## **Building and Control Room**

There is a control/chemical room which houses the tertiary filtration unit, chemical dosing systems, blowers and all associated electrical equipment.

## **Digester Unit**

The digester unit consists of a digester tank equipped with fine bubble aeration used for sludge stabilization and storage that came from the SBR's. The supernatant is returned back to the influent while the sludge is periodically hauled to either Ravensview Wastewater Treatment Plant or Cataraqui Bay Wastewater Treatment Plant in the City of Kingston for further treatment.

## PLANT PERFORMANCE

ECA # 4021-9WUKDE was issued on July 22, 2015 for the new constructed WPCP plant to replace the 44 year old plant. The conditions contained within ECA # 4021-9WUKDE apply to the new WWTP starting in January 2017.

The following tables summarize the results obtained through monitoring of plant performance:

**Table 1: Effluent Objective**

Effluent Objectives and Limits		
Effluent Parameter	Objective (mg/l)	Limits (mg/l)
CBOD <sub>5</sub>	5.0 (Monthly Average)	10 (Annual Average)
Total suspended solids (TSS)	5.0 (Monthly Average)	10 (Annual Average)
Total Phosphorus	0.1 (Monthly Average)	0.2
Total Ammonia Nitrogen	2.0 (Winter, Oct. to Mar.)	3 Winter
	1.0 (summer, April to Sept.)	2 Summer
E. coli.	100 CFU/100 millilitres	200 CFU/100mL

Note: pH maintained between 6.5 to 8.5 at all times.

**Table 2: Monthly Average Results**

Monthly Average Results							
Month	CBOD5 mg/l	TSS mg/l	Total Phosphorus mg/l	Total Ammonia Nitrogen	pH	E.coli. CFU/100mL	Acute Lethality
January	2	10	0.16	1.38	7.65	5	
February	1	5	0.09	0.34	7.93	1	
March	2	3	0.08	0.55	8.04	0	
April	1	8	0.19	0.24	8.17	1	PASS
May	1	7	0.20	.008	8.23	0	
June	1	5	0.13	0.05	8.19	0	
July	1	3	0.11	0.03	8.16	0	
August	1	6	0.11	0.01	8.09	0	
September	1	3	0.04	0.01	8.11	0	PASS
October	1	4	0.04	0.03	8.18	1	
November	2	5	0.07	0.19	8.06	1	
December	2	4	0.03	0.38	8.04	0	
Annual Average	1.53	5.25	0.11	0.27	8.07	0.75	

**Table 3: Plant Flows**

Flows				
Parameter	2015	2016	2017	2018
Avg. m <sup>3</sup> /day	86.72	90.34	137.67	126.58
Max. m <sup>3</sup> /day	223	275	202.00	189.25
Design. m <sup>3</sup> /day	94.6	94.6	125	125
Peak m <sup>3</sup> /day			200	200
% (daily/design)	91.7%	95.5%	110.14%	101.26%

**Table 4: Surface Water Monitoring**

Surface Water Monitoring								
	CBOD mg/l	TSS mg/l	TP mg/l	Total Ammonia Nitrogen mg/l	Nitrate nitrogen mg/l	E.coli	pH	Temp
<b>UPSTREAM</b>								
11/04/18	1	3	0.05	0.02	0.2	1	8.28	6.6
06/09/18	NO	FLOW						
<b>DOWNSTREAM</b>								
11/04/18	2	3	0.07	0.05	0.9	1	8.23	9
06/09/18	2	3	0.05	0.02	3.7	2	8.06	7

**Table 5: Reportable Bypasses**

Bypasses					
Date	Start	Duration (hrs)	Volume (m3)	Reason	Precip. (mm)
12/01/18	00:10	25	135	Heavy rain	18.8
20/02/18	16:51	23.15	112.71	Snow/rain	26
17/04/18	11:31	12.86	38.93	Heavy rain	30.2
15/08/18	08:30	11.27	41.22	Heavy rain	25.7



**Table 6: Reportable Bypass Sampling**

<b>Bypass Event Sampling Results</b>		
<b>Parameter</b>	<b>Units</b>	<b>CANA STP Annual Avg.</b>
E coli	Cfu/100mL	2629
CBOD5	mg/l	5.25
TSS	mg/l	47.25
TP	mg/l	1.53
Total Ammonia	mg/l	0.24

## **OPERATING PROBLEMS**

Modifications to the process piping and changing out of check valves helped to deal with operational challenges experience when the plant first came online in 2017. Staff continued to optimize the plant processes to ensure continuous, reliable operations.

## **SLUDGE GENERATED**

There were 3 loads (total volume of 185 m<sup>3</sup>) of sludge collected and brought to Ravensview Wastewater Treatment Plant. The sludge was discharged at the septage facility. There will be approximately the same amount of sludge removed in 2019.

## **MAINTENANCE**

In 2018 we continued with our preventative maintenance program in accordance with manufacturer’s recommendations.

The following bullet points highlight additional maintenance completed this year.

- Modifications to routing of process piping to address operational issues
- Replaced two check valves
- Analyzer relocation

## **CAPITAL WORKS**

There were no capital works done in 2018 as the plant is newly constructed.

## **OPERATIONS**

Preventative maintenance and regular process and equipment inspections lead to operational problems being diagnosed quickly and corrective actions implemented immediately.

## **EQUIPMENT CALIBRATIONS**

All Utilities Kingston plant flow meters, online analyzers and lab equipment are calibrated annually by third party contractors. As a result of this proactive approach, the facility saw limited downtime of major equipment and saw very few mechanical or electrical failures this year. Calibration records are available upon request.

## **COMPLAINTS**

There have been no official complaints about the CANA Wastewater Treatment Plant operations for the reporting year 2018.

## **BYPASS**

There have been four bypasses for the CANA Wastewater Treatment Plant operations for the reporting year 2018 (please see Tables 5 and 6).