
Facility: Lead Samples Non Residential

Lead (dissolved)

# samples:	16	min:	0.00012 mg/L	Ministry of Environment Lead Standard is 0.01 mg/l
# exceedances:	2	max:	0.0225 mg/L	
		avg:	0.00346 mg/L	

Facility: Lead Samples Residential

Lead (dissolved)

# samples:	172	min:	< 0.00002 mg/L	Ministry of Environment Lead Standard is 0.01 mg/l
# exceedances:	1	max:	0.0136 mg/L	
		avg:	0.00226 mg/L	

Result Legend:

< means less than lower detection limit shown